



**GAQF.EX15573  
Clean-agent Extinguishing System Units**

Page Bottom

**Clean-agent Extinguishing System Units**

See General Information for Clean-agent Extinguishing System Units

**EVERSAFE EXTINGUISHER SDN BHD**

EX15573

LOT 878  
JALAN SUBANG 9  
TAMAN PERINDUSTRIAN SUBANG  
47500 SUBANG JAYA, SELANGOR MALAYSIA

**ENGINEERED UNITS**, NAF S 125 (HFC-125 with limonene additive, 0.15% by weight) Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 5, 13.4, 26.8, 40.2, 67.5, 75, 100 and 120 L. The units are super pressurized to 42 bar at 21°C with operating temperatures of 0 °C to +50 °C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual P/N SHIM125227 Rev. 02 dated December 2014 and design manual P/N SHDM125 dated February 2014. These installations require the use of the Listee's flow calculation software NAF S 125 Flow Calculation Program Version SHT 4.00 dated July 2014 floppy disc or CD accessed through Safety Hi-Tech, User's Manual SHT 4.00. Copies are available from the above Listee.

**AGENT STORAGE CONTAINER ASSEMBLY**

Weight of Agent (kg)	Part No.
2.5-4.0	SH70025410
6.5-12.5	SH70025409
13.0-24.5	SH70025408
19.5-37.0	SH70025407
32.5-62.0	SH70025412
36.0-70.5	SH70025405
48.5-93.0	SH70025404
58.0-111.5	SH70025403

**ENGINEERED UNITS**, NAF S 125 (HFC-125 with limonene additive, 0.15% by weight) Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 26.8, 40.2, 75, 120, 142, 175 and 240 L. The units are super pressurized to 25 bar at 21°C with operating temperatures of 0 °C to + 50 °C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual P/N SHIM125227 Rev. 02 dated December 2014 and design manual P/N SHDM125 dated February 2014. These installations require the use of the Listee's flow calculation software NAF S 125 Flow Calculation Program Version SHT 4.00 dated July 2014 floppy disc or CD accessed through Safety Hi-Tech, User's Manual SHT 4.00. Copies are available from the above Listee.

**AGENT STORAGE CONTAINER ASSEMBLY**

Weight of Agent (kg)	Part No.
13.0-24.5	SH72525408
19.5-37.0	SH72525407
36.0-70.5	SH72525405
58.0-111.5	SH72525403
68.5-132.0	SH70025413
84.5-162.5	SH70025414
115.5-223.0	SH70025415

**ENGINEERED UNITS**, NAF S 227 (HFC-227ea with limonene additive, 0.15% by weight) Clean Agent Extinguishing Systems Units, stored pressure types, having nominal capacities of 5, 13.4, 26.8, 40.2, 67.5, 75, 100 and 120L. The units are super pressurized to 42 bar at 21°C with operating temperatures of 0 °C to + 50 °C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual P/N SHIM125227 Rev. 02 dated December 2014 and design manual P/N SHDM227 dated February 2014. These installations require the use of the Listee's flow calculation software NAF S 227® Flow Calculation Software Version SHT 4.00 dated July 2014 floppy disc or CD accessed through Safety Hi-Tech, User's Manual SHT 4.00. Copies are available from the above Listee.

**AGENT STORAGE CONTAINER ASSEMBLY**

<b>Weight of Agent (kg)</b>	<b>Part No.</b>
2.5-5.5	SH70027410
6.5-15.0	SH70027409
13.0-30.5	SH70027408
19.5-46.0	SH70027407
32.5-77.0	SH70027412
36.5-86.0	SH70027405
48.5-115.0	SH70027404
58.0-138.0	SH70027403

**ENGINEERED UNITS**, NAF S 227 (HFC-227ea with limonene additive, 0.15% by weight) Clean Agent Extinguishing System Units, stored pressure type, having nominal capacities of 26.8, 40.2, 75, 120, 142, 175 and 240 liters. The units are super pressurized to 25 bar at 21°C with operating temperature of 0 °C to + 50 °C. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual P/N SHIM125227 Rev. 02 dated December 2014 and design manual P/N SHDM227 dated February 2014. These installations require the use of the Listee's flow calculation software NAF S 227® Flow Calculation Software Version SHT 4.00 dated July 2014 floppy disc or CD accessed through Safety Hi-Tech, User's Manual SHT 4.00. Copies are available from the above Listee.

**AGENT STORAGE CONTAINER ASSEMBLY**

<b>Weight of Agent (kg)</b>	<b>Part No.</b>
13.0-30.5	SH72527408
19.0-46.0	SH72527407
36.5-86.0	SH72527405
58.0-138.0	SH72527403
68.5-159.0	SH70027413
84.5-196.0	SH70027414
115.5-268.5	SH70027415

Last Updated on 2015-01-07

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".